



INSTALLATION GUIDELINES and GENERAL INFORMATION:

1. See the specific system wiring diagram for the balance of the wiring connections required.
2. All low voltage wiring is #18 AWG, unless otherwise noted.
3. Observe all local and national electrical and building codes.
4. Each system is wired independently and uses an independent 24VAC (model SS106) transformer (or equivalent).
5. Wiring shown is applicable to our model EK117 and/or EK154 Emergency-Call kits only.
6. Wire colors shown are the pigtail wires on the back of the SF117/2A pull cord station(s) and SF154A Push Stations, and CDL101LED Dome Lights.



42 Central Drive, Farmingdale NY 11735-1202
 (631) 777-5500 Fax: (631) 777-5599
TOLL-FREE Technical Line 1-800-666-4800
 Email: info@alphacommunications.com

TYPICAL WIRING INSTRUCTIONS FOR EK117 Series and EK154 Series

Emergency Call Kits with CDL101LED Dome Light and separate SS106 transformer for each light unit.