



INSTALLATION GUIDELINES and GENERAL INFORMATION:

1. See the specific system wiring diagram for the balance of the wiring connections required.
2. All low voltage wiring is #18 AWG, unless otherwise noted.
3. Observe all local and national electrical and building codes.
4. DO NOT exceed recommended voltages.
5. When used with a magnetic door lock, a separate DC power supply is required for the magnetic door lock.
6. Although the standard input for the PK407A is 16VAC, the PK407A will accept an input voltage of 12VAC to 16VAC. Do not connect to 24VAC!!



42 Central Drive, Farmingdale NY 11735-1202
(631) 777-5500 Fax: (631) 777-5599
TOLL-FREE Technical Line 1-800-666-4800
Email: info@alphacommunications.com

TYPICAL WIRING INSTRUCTIONS FOR PK407A SPECIALTY RELAY UNIT

Showing Normally Open and Normally Closed
Form 'C' Relay Contacts