

**NOTES: All wiring #18AWG unless shown otherwise.**


**All connections shown with dotted lines are optional wiring configurations.**

**Do not connect the SS106 transformer to the AC219 or SK019 unit(s).**

**Use the 24VAC connections on the SS106 transformer.**

**Terminal connections shown may not be in the actual order they appear on the equipment.**

**For balance of system wiring, please see the specific AlphaEcall™, CM800 or DS100 installation manual.**

 <p>42 Central Drive, Farmingdale NY 11735-1202 (631) 777-5500 Fax: (631) 777-5599 TOLL-FREE Technical Line 1-800-666-4800 Email: info@alphacommunications.com</p>	<p><b>Typical Wiring Diagram for the AC219 control unit with the PK124 battery charger, for AlphaEcall™, CM800 and/or DS100 systems.</b></p>
---	--