


NOTES: Wiring can be standard #24AWG twisted pair telephone wiring.

24vdc power Plus (+) is connected to TB1-5 and Negative (-) is connected to TB1-6. The PSDC24-1.3 power supply needs to be directly connected to one (1) CC201 Master Station only, and then the power is jumpered to the other Master Station via the cable (PAIR #3)

Terminal connections shown may not be in the actual order they appear on the equipment.

 <p>42 Central Drive, Farmingdale NY 11735-1202 (631) 777-5500 Fax: (631) 777-5599 TOLL-FREE Technical Line 1-800-666-4800 Email: info@alphacommunications.com</p>	<p>Typical Wiring Diagram for the CC201 series Clean Room Intercom System showing a single system with two (2) Master Stations</p>
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------